

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50481055

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*
L.X.F.

Unser Zeichen *Our Reference*
01-DJL-NN2003HH 001

Ausstellungsdatum
25.09.2020

Date of Issue
(day/mo/yr)

Genehmigungsinhaber *License Holder*

SUNTREE Electric Group Co., Ltd.
Xinguang Industrial Zone,
Liushi Town, Yueqing City
Zhejiang
P.R. China

Fertigungsstätte *Manufacturing Plant*

SUNTREE Electric Group Co., Ltd.
Xinguang Industrial Zone,
Liushi Town, Yueqing City
Zhejiang
P.R. China

Prüfzeichen *Test Mark*



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1111229615

Geprüft nach *Tested acc. to*
EN 60947-2:2017+A1

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Circuit Breaker (DC Miniature Circuit Breaker)

Type Designation	: SL7N-63 (Suntree)	8
Intended for Use	: Photovoltaic (PV) systems	
Reference Temperature	: +40°C	
Utilization Category	: A	
Number of Poles	: 1) 1P Appearance 2) 2P Appearance 3) 3P Appearance 4) 4P Appearance	
Rated Operation Voltage (Ue)	: 1) DC 15/24/48/60/100/180/250V 2) DC 24/48/125/375/500/550/600/800V 3) DC 750/900V 4) DC 1000/1200V	
Rated Current (In)	: 6/10/16/20/25/32/40/50/63A	
Instantaneous Tripping Curve	: Ii=10In (for C-type) Ii=5In (for B-type)	

Continued on page 0002

ANLAGE (Appendix): 1

8

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



Kenny Shi